

**Government of Bihar
Public Health Engineering Department**

DISTRICT :- SAMASTIPUR				DIVISION :- SAMASTIPUR													MONTH:-FEBUARY 2026			
S.N.	BLOCK	PANCHAYAT	LOCATION OF SOURCE	PARAMETERS													REMARKS			
				pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	T.COIL						
1	HASANPUR	SHAKARPURA	PROGRESSIVE CENTRAL SCHOOL (SAKARPURA HASANPUR)	7.1	1	165	107	64	18	22	10	72	0.1	-Ve						
Acceptable Limit as per BIS 10500/2012				6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250mg/l	30 mg/l	200 mg/l	1.0mg/l	-						
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012				NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR	-						

Sam
66/02/26
Chemist /Lab Assistant
P.H. Division Samastipur

Patil
JE
P.H.Sub Division Samastipur

Patil
Assistant Engineer
66/02/26
P.H.Sub Division Samastipur

Patil
Executive Engineer
66/02/26
P.H. Division Samastipur